



## FF-45/60

# 45 and 60 minute wood door frames

Category C “Proprietary Frame” – Intumescent/wood door frame for installation in 45 or 60 minute locations in steel/wood/drywall or masonry openings. Category A, Category B or Neutral Pressure fire rated wood/composite doors may be used.

**Category G Edge Sealing System is NOT required.**

Frame can also be used as a communicating frame.

Maximum opening size:	Single swing - 42” wide x 96” high
Minimum frame leg width:	4-5/8”
Maximum frame leg width:	Equivalent to wall thickness
Minimum Frame thickness:	3/4” (-1/16”)
Minimum Rabbet for door:	1-7/8” (-1/16”)
Stop:	single rabbet or double rabbet (applied: flat laminated or “T” stop)
Minimum stop height:	1/2”
Minimum stop width:	1-1/4” (-1/8”)
Face material:	Wood, wood veneers (minimum density = 18 pcf)
Casing:	Minimum 5/16” x 1-1/2” soft wood.

Patent Pending